

วัน	ไฟฟ้า (kW)			อัตราการไหลน้ำเย็น (GPM)	อุณหภูมิน้ำเย็น (°F)		DT(°F)	อัตราการทำความเย็น (TR)	สมรรถนะการทำความเย็น (kW/TR)
	Chiller1	Chiller2	Total		เข้า	ออก			
6/3/2013 9:00	87.55	74.23	161.77	571.43	52.79	46.13	6.66	158.57	1.02
6/3/2013 9:01	87.61	74.08	161.69	571.14	52.61	46.04	6.57	156.35	1.03
6/3/2013 9:02	87.50	74.22	161.72	575.27	52.43	45.95	6.48	155.32	1.04
6/3/2013 9:03	87.60	74.36	161.96	582.96	52.43	45.95	6.48	157.40	1.03
6/3/2013 9:04	87.73	74.29	162.02	573.21	52.34	45.68	6.66	159.06	1.02
6/3/2013 9:05	87.78	74.19	161.97	581.18	52.34	45.86	6.48	156.92	1.03
6/3/2013 9:06	88.01	74.39	162.40	578.23	52.34	45.77	6.57	158.29	1.03
6/3/2013 9:07	87.86	74.31	162.18	580.59	52.07	45.68	6.39	154.58	1.05
6/3/2013 9:08	88.21	74.42	162.63	572.91	52.07	45.68	6.39	152.54	1.07
6/3/2013 9:09	88.51	74.25	162.75	577.05	52.07	45.68	6.39	153.64	1.06
6/3/2013 9:10	87.94	74.24	162.18	574.39	51.98	45.41	6.57	157.24	1.03
6/3/2013 9:11	87.88	74.40	162.28	572.62	51.89	45.41	6.48	154.61	1.05
6/3/2013 9:12	88.17	74.44	162.61	579.71	51.89	45.41	6.48	156.52	1.04
6/3/2013 9:13	88.01	74.27	162.28	576.16	51.89	45.23	6.66	159.88	1.01
6/3/2013 9:14	88.10	74.65	162.75	578.23	51.80	45.23	6.57	158.29	1.03
6/3/2013 9:15	88.08	74.57	162.65	577.64	51.62	45.14	6.48	155.96	1.04
6/3/2013 9:16	88.25	74.56	162.80	571.43	51.80	45.23	6.57	156.43	1.04
6/3/2013 9:17	88.52	74.65	163.17	572.62	51.80	45.23	6.57	156.75	1.04
6/3/2013 9:18	88.36	74.37	162.73	576.75	51.71	45.32	6.39	153.56	1.06
6/3/2013 9:19	89.62	74.48	164.10	572.02	51.80	45.41	6.39	152.30	1.08
6/3/2013 9:20	88.79	74.73	163.52	571.73	51.80	45.41	6.39	152.22	1.07
6/3/2013 9:21	89.03	74.92	163.96	574.68	51.80	45.32	6.48	155.16	1.06
6/3/2013 9:22	88.67	74.74	163.42	576.46	51.80	45.41	6.39	153.48	1.06
6/3/2013 9:23	88.55	74.66	163.22	565.52	51.71	45.41	6.30	148.45	1.10
6/3/2013 9:24	88.54	74.63	163.17	575.27	51.71	45.23	6.48	155.32	1.05
6/3/2013 9:25	88.33	74.74	163.07	574.68	51.80	45.41	6.39	153.01	1.07
6/3/2013 9:26	88.43	74.52	162.95	578.82	51.80	45.32	6.48	156.28	1.04
6/3/2013 9:27	88.55	74.88	163.43	582.37	51.53	45.23	6.30	152.87	1.07
6/3/2013 9:28	88.82	74.95	163.78	580.89	51.80	45.41	6.39	154.66	1.06
6/3/2013 9:29	89.01	75.23	164.24	576.46	51.71	45.23	6.48	155.64	1.06
6/3/2013 9:30	89.31	74.97	164.28	578.82	51.53	45.14	6.39	154.11	1.07
6/3/2013 9:31	88.95	74.90	163.85	581.18	51.62	45.14	6.48	156.92	1.04
6/3/2013 9:32	88.89	74.96	163.85	585.32	51.62	45.23	6.39	155.84	1.05
6/3/2013 9:33	90.23	75.11	165.34	576.16	51.62	45.14	6.48	155.56	1.06
6/3/2013 9:34	88.93	75.43	164.36	577.05	51.62	45.23	6.39	153.64	1.07
6/3/2013 9:35	88.97	75.22	164.19	581.18	51.62	45.23	6.39	154.74	1.06
6/3/2013 9:36	89.04	74.99	164.03	572.32	51.62	45.23	6.39	152.38	1.08
6/3/2013 9:37	88.90	75.02	163.93	573.80	51.62	45.32	6.30	150.62	1.09
6/3/2013 9:38	88.99	75.25	164.24	579.12	51.53	45.23	6.30	152.02	1.08
6/3/2013 9:39	89.29	75.42	164.71	590.05	51.53	45.14	6.39	157.10	1.05
6/3/2013 9:40	89.39	75.23	164.62	582.37	51.53	45.23	6.30	152.87	1.08
6/3/2013 9:41	89.43	75.74	165.18	585.32	51.44	45.14	6.30	153.65	1.08
6/3/2013 9:42	90.04	76.16	166.20	587.98	51.35	44.96	6.39	156.55	1.06
6/3/2013 9:43	89.94	75.91	165.84	579.71	51.53	45.05	6.48	156.52	1.06
6/3/2013 9:44	90.18	75.89	166.07	566.71	51.35	44.96	6.39	150.89	1.10
6/3/2013 9:45	89.69	75.91	165.59	574.68	51.35	44.96	6.39	153.01	1.08
6/3/2013 9:46	90.22	76.14	166.36	577.05	51.53	45.05	6.48	155.80	1.07
6/3/2013 9:47	90.12	76.08	166.20	574.09	51.35	44.96	6.39	152.85	1.09
6/3/2013 9:48	90.01	75.95	165.96	571.73	51.44	44.87	6.57	156.51	1.06
6/3/2013 9:49	89.83	76.17	166.00	583.84	51.44	45.05	6.39	155.45	1.07
6/3/2013 9:50	89.85	75.98	165.82	569.37	51.44	45.05	6.39	151.59	1.09
6/3/2013 9:51	89.96	75.78	165.73	574.68	51.35	44.96	6.39	153.01	1.08
6/3/2013 9:52	90.09	76.25	166.34	573.21	51.53	45.05	6.48	154.77	1.07
6/3/2013 9:53	91.09	76.72	167.81	575.27	51.35	44.96	6.39	153.17	1.10
6/3/2013 9:54	90.20	76.28	166.47	581.48	51.26	44.87	6.39	154.82	1.08

วัน	ไฟฟ้า (kW)			อัตราการไหลน้ำเย็น (GPM)	อุณหภูมิน้ำเย็น (°F)		DT(°F)	อัตราการทำความเย็น (TR)	สมรรถนะการทำความเย็น (kW/TR)
	Chiller1	Chiller2	Total		เข้า	ออก			
6/3/2013 9:55	90.24	76.17	166.40	568.77	51.44	45.05	6.39	151.44	1.10
6/3/2013 9:56	89.94	76.44	166.38	579.12	51.35	44.96	6.39	154.19	1.08
6/3/2013 9:57	90.02	75.93	165.94	570.84	51.44	44.96	6.48	154.13	1.08
6/3/2013 9:58	89.46	75.91	165.37	576.75	51.44	45.05	6.39	153.56	1.08
6/3/2013 9:59	89.59	76.25	165.84	575.27	51.44	45.05	6.39	153.17	1.08
6/3/2013 10:00	91.03	76.51	167.54	572.62	51.35	44.96	6.39	152.46	1.10
6/3/2013 10:01	89.87	76.35	166.22	572.91	51.26	44.96	6.30	150.39	1.11
6/3/2013 10:02	90.40	76.84	167.24	576.75	51.53	45.05	6.48	155.72	1.07
6/3/2013 10:03	90.08	77.09	167.16	574.09	51.44	45.05	6.39	152.85	1.09
6/3/2013 10:04	90.58	77.46	168.03	574.09	51.44	44.96	6.48	155.01	1.08
6/3/2013 10:05	90.87	77.73	168.60	572.02	51.26	44.87	6.39	152.30	1.11
6/3/2013 10:06	90.50	77.63	168.14	576.46	51.35	44.87	6.48	155.64	1.08
6/3/2013 10:07	90.94	77.79	168.73	573.21	51.35	44.96	6.39	152.62	1.11
6/3/2013 10:08	90.84	77.38	168.22	572.91	51.26	44.69	6.57	156.83	1.07
6/3/2013 10:09	90.98	77.24	168.22	574.39	51.26	44.96	6.30	150.78	1.12
6/3/2013 10:10	91.05	77.25	168.30	572.32	51.26	44.96	6.30	150.23	1.12
6/3/2013 10:11	90.79	77.78	168.57	575.27	51.26	44.87	6.39	153.17	1.10
6/3/2013 10:12	90.33	77.11	167.44	582.66	51.35	44.96	6.39	155.13	1.08
6/3/2013 10:13	89.87	76.98	166.86	577.64	51.44	44.96	6.48	155.96	1.07
6/3/2013 10:14	90.36	76.85	167.22	574.39	51.26	44.96	6.30	150.78	1.11
6/3/2013 10:15	89.99	76.85	166.83	581.77	51.26	44.87	6.39	154.90	1.08
6/3/2013 10:16	90.52	77.37	167.90	576.46	51.44	45.05	6.39	153.48	1.09
6/3/2013 10:17	90.46	77.46	167.93	585.02	51.35	44.87	6.48	157.96	1.06
6/3/2013 10:18	91.42	77.32	168.74	582.37	51.26	44.87	6.39	155.05	1.09
6/3/2013 10:19	90.37	77.34	167.71	581.77	51.26	44.87	6.39	154.90	1.08
6/3/2013 10:20	90.78	77.69	168.47	583.25	51.26	44.87	6.39	155.29	1.08
6/3/2013 10:21	90.83	77.75	168.58	581.77	51.26	44.78	6.48	157.08	1.07
6/3/2013 10:22	90.19	77.25	167.43	579.41	51.26	44.87	6.39	154.27	1.09
6/3/2013 10:23	90.05	77.52	167.57	583.25	51.26	44.87	6.39	155.29	1.08
6/3/2013 10:24	90.61	77.80	168.40	576.16	51.26	44.87	6.39	153.40	1.10
6/3/2013 10:25	90.79	78.12	168.90	569.96	51.26	44.78	6.48	153.89	1.10
6/3/2013 10:26	90.50	77.73	168.23	572.32	51.26	44.87	6.39	152.38	1.10
6/3/2013 10:27	90.17	77.60	167.77	572.91	51.26	44.87	6.39	152.54	1.10
6/3/2013 10:28	91.68	77.71	169.39	573.50	51.26	44.87	6.39	152.69	1.11
6/3/2013 10:29	90.22	77.43	167.66	568.77	51.35	44.96	6.39	151.44	1.11
6/3/2013 10:30	90.20	77.66	167.86	576.46	51.26	44.96	6.30	151.32	1.11
6/3/2013 10:31	89.58	77.22	166.81	574.09	51.35	45.05	6.30	150.70	1.11
6/3/2013 10:32	89.91	77.34	167.25	577.34	51.44	45.05	6.39	153.72	1.09
6/3/2013 10:33	90.08	77.86	167.93	574.68	51.53	45.14	6.39	153.01	1.10
6/3/2013 10:34	90.12	77.94	168.05	568.18	51.26	45.05	6.21	147.02	1.14
6/3/2013 10:35	89.84	77.68	167.52	571.14	51.26	44.87	6.39	152.07	1.10
6/3/2013 10:36	89.93	77.64	167.57	567.00	51.26	44.87	6.39	150.96	1.11
6/3/2013 10:37	90.02	77.54	167.56	568.18	51.35	45.05	6.30	149.15	1.12
6/3/2013 10:38	90.04	77.77	167.81	565.23	51.35	44.96	6.39	150.49	1.12
6/3/2013 10:39	89.93	77.90	167.84	581.18	51.35	44.87	6.48	156.92	1.07
6/3/2013 10:40	90.01	77.63	167.64	572.32	51.35	45.05	6.30	150.23	1.12
6/3/2013 10:41	90.06	77.90	167.95	573.80	51.44	45.05	6.39	152.77	1.10
6/3/2013 10:42	90.30	78.11	168.41	572.32	51.35	45.14	6.21	148.09	1.14
6/3/2013 10:43	90.14	78.17	168.31	573.80	51.35	45.05	6.30	150.62	1.12
6/3/2013 10:44	90.93	77.34	168.27	574.09	51.26	45.05	6.21	148.55	1.13
6/3/2013 10:45	88.87	77.43	166.31	571.73	51.44	45.14	6.30	150.08	1.11
6/3/2013 10:46	89.54	78.10	167.64	583.84	51.53	45.23	6.30	153.26	1.09
6/3/2013 10:47	89.41	77.69	167.09	569.37	51.53	45.23	6.30	149.46	1.12
6/3/2013 10:48	89.07	77.40	166.47	569.37	51.44	45.14	6.30	149.46	1.11
6/3/2013 10:49	89.86	78.28	168.13	574.68	51.62	45.32	6.30	150.85	1.11

วัน	ไฟฟ้า (kW)			อัตราการไหลน้ำเย็น (GPM)	อุณหภูมิน้ำเย็น (°F)		DT(°F)	อัตราการทำความเย็น (TR)	สมรรถนะการทำความเย็น (kW/TR)
	Chiller1	Chiller2	Total		เข้า	ออก			
6/3/2013 10:50	90.13	78.55	168.68	574.39	51.53	45.23	6.30	150.78	1.12
6/3/2013 10:51	90.69	79.02	169.71	572.62	51.44	45.14	6.30	150.31	1.13
6/3/2013 10:52	90.00	78.38	168.39	579.71	51.44	44.96	6.48	156.52	1.08
6/3/2013 10:53	89.58	78.49	168.07	576.16	51.35	45.14	6.21	149.08	1.13
6/3/2013 10:54	90.36	78.95	169.30	578.23	51.62	45.23	6.39	153.95	1.10
6/3/2013 10:55	89.97	78.73	168.70	579.71	51.26	44.96	6.30	152.17	1.11
6/3/2013 10:56	90.11	79.01	169.12	576.16	51.35	45.05	6.30	151.24	1.12
6/3/2013 10:57	89.25	78.14	167.40	578.23	51.53	45.23	6.30	151.79	1.10
6/3/2013 10:58	89.75	78.56	168.31	577.64	51.53	45.32	6.21	149.46	1.13
6/3/2013 10:59	90.39	78.30	168.69	571.43	51.44	45.14	6.30	150.00	1.12
6/3/2013 11:00	90.20	78.01	168.20	569.37	51.44	45.14	6.30	149.46	1.13
เฉลี่ย	89.62	76.42	166.04	575.86	51.54	45.14	6.40	153.55	1.08
สูงสุด	91.68	79.02	169.71	590.05	52.79	46.13	6.66	159.88	1.14
ต่ำสุด	87.50	74.08	161.69	565.23	51.26	44.69	6.21	147.02	1.01